



METROPOLITAN
WASTE
CONTROL
COMMISSION
Twin Cities Area

June 5, 1986

EPA Region 5 Records Ctr.



387912

Robert Henretta
Henretta, Lamm & Cross, Attorneys at Law
10285 Yellow Circle Drive
Minnetonka, MN 55343

RE: Discharge of Contaminated Groundwater

Mr. Henretta:

A request to discharge contaminated groundwater from the site of Interplastics Corporation was received by the MWCC. The request was made by Roger Hatcher of Hatcher, Inc., Richmond, Virginia. Permission to discharge to the sanitary sewer 12,000 gallons of well development water and other contaminated groundwater of like quality needed to be extracted in the cleanup of groundwater at this facility. The permission is conditional based on the following:

1. All discharges shall occur over a seven month period commencing June 1, 1986. Any future discharges beyond 1/1/87 will call for re-application for permission to discharge.
2. Monthly reports shall be submitted to the MWCC (Michael Pliml) until the discharge ceases. These reports shall contain developments occurring during the month regarding cleanup operations, the volume discharged to the sanitary sewer and at minimum analytical results of at least one sample taken during the month to characterize discharge quality.
3. The location of discharge and maximum flow rates should be arranged with the City of Minneapolis (Chris Schaffer 729-7425).
4. When pumping commences of groundwater discharged directly to the sanitary sewer a meter shall be installed to record the volume discharged. Records shall be kept of the volumes and reported on monthly basis to the City of Minneapolis (Glen Kiecker) and the MWCC. Sewer charges can then be arranged with the City of Minneapolis.
5. A representative from the MWCC shall inspect the cleanup operation prior to and during discharge occurrence. Therefore, notification of discharge commencement shall be given the MWCC 48 hours prior to start up.

Robert Henretta

2

June 5, 1986

6. If excessive odor results from the pumping and discharge of this contaminated groundwater, treatment to reduce the odors may be required.
7. Any and all additional conditions for this discharge set forth by either the City of Minneapolis or the MPCA shall be complied with. The MWCC reserves the right to inspect/sample this discharge at any time during discharge. This approval may be revoked at any time by the MWCC, if deemed necessary.

If you have any questions, please call me at 772-7109.

Sincerely,

Michael Pliml

Michael Pliml
Staff Engineer
Industrial Waste Division

MWP:pf

CC: Glenn Kiecker, City of Minneapolis
Chris Schaffer, City of Minneapolis
L.H. Hermes, MWCC
B.J. Loida, MWCC
Dick Kable, MPCA
R.F. Hatcher, Hatcher, Inc.

